



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Azad Hind Sarak, P.O.:- Ghurni, P.S.:- Kotwali, Pin :- 741103

Memo No.:FSR/211862506300014964

Date : 12-05-2026

From :
Divisional Fire Officer
Nadia Division,
West Bengal Fire & Emergency Services

To :
Holy Angels Academy (h.a.a.)
VILL-DAYER BAZAR,P.O-DAYER BAZAR,P.S-CHAPRA,DIST-NADIA,PIN-741164

Sub : Fire Safety Certificate for Existing construction of G+I storied building under group of Educational building in the name & style of "HOLY ANGELS ACADEMY (H.A.A)" at the premises :Vill+P.O: Dayerbazar, P.S: Cahpra, Dist:Nadia, Pin:741164, West Bengal.

This is in reference to your AIN 211892606300010590 dated 28-Apr-2026 regarding Fire Safety Certificate for Existing construction of G+I storied building under group of Educational building in the name & style of "HOLY ANGELS ACADEMY (H.A.A)" at the premises :Vill+P.O: Dayerbazar, P.S: Cahpra, Dist:Nadia, Pin:741164, West Bengal. .

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

1. Good housekeeping shall always be maintained.
2. Necessary precautions shall always be taken during storing , processing , handling , using raw & finished Jute and careful about any fiction in the machinery during processing of jute to avoid any incident.
3. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892606300010590

4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
5. The Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in the them , Particularly lines above false ceiling & ducts. Electrical safety Audit to be conducted positively by 31st March every years.
6. A fire control room including a close circuit T.V system will have to be installed which observe all floor of the building podium shall be incorporate with the system.
7. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at the venerable of the building.
8. The employees and security staff shall be conversant with installed Fire fighting equipment of the building and to operate in the event of Fire & testing.
9. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupancy of the building.
10. A crew of trained Fire man under experience officer shall be maintained round the clock for Fire Safety of the building.
11. **O.H.W.R 2000 LTRS. Existed but 10000 ltrs shall be provided within 03(three) month's from the date of issue of this letter & inform to this office otherwise treated as canceller.**
12. **One no(01) stand-by pump shall be provided within 03(three) month's from the date of issue of this letter & inform to this office otherwise treated as canceller.**
13. **IRON staircase as per plan drawing ground floor to roof level having width 1 M. shall be provided within 01(one) month from the date of issue of this letter & inform to this office otherwise treated as canceller.**
14. The inertial finish decoration of building shall be made with low flame spread material confirming of I.S specification.
15. The First Aid Fire Fighting arrangement in the style of placing suitable Fire Extinguisher , Fire buckets etc shall be provided where not provided.
16. Periodical flashing of water in the hydrant and sprinkler pipe line shall be made to maintain the efficiency working performance of above mention system.
17. The Fire Safety audit to be conducted a regular interval and the be record in the Fire Prevention maintenance register.
18. This Fire Safety Certificate is valid for three years and have to be renewed every three years interval from the date of issue of this letter. In every three years Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, regarding the performance of all the life & Fire Safety arrangement and installation of the building.
19. Any deviation or changes the building in respect of the approved plan drawing , without prior permission from this office this Fire Safety Certificate will be treated cancelled automatically.

Valid Upto : 10-May-2029



Signature valid

Digitally Signed.
Name: SUBNATA CHHA
Date: 12-May-2025 11:04:44
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892606300010590